

GULFSTAR RADIATOR COOLANT

Industrial Oil

Typical Characteristics

TESTS	TEST METHOD	33% COOL	50% COOL
COLOR	VISUAL	FLOUROSCENT GREEN	FLOUROSCENT GREEN
Density, G/ML	ASTM D 1122	1.05-1.055	1.06- 1.065
BOILLING POINT°C	ASTM D-1120	120	125
FREEZING POINT °C	ASTM D-1177	-33	-39
ASH CONTENT % MASS	ASTM D 1119	0.5	0.4
RESERVE ALKALINITY	ASTM D1127-	2.6	2.88
PH VALUE	ASTM D1177-	9.0	8.85